


Il progetto



La rete idrica



Le tubazioni

Link ID	Flow LPM	Velocity m/s	Unit Headloss m/km	Friction Factor R
Pipe 2	-18.00	0.15	0.84	0.035
Pipe 3	18.00	0.61	24.08	0.032
Pipe 4	6.00	0.05	0.08	0.029
Pipe 5	6.00	0.05	0.08	0.029
Pipe 6	6.00	0.05	0.08	0.029
Pipe 7	6.00	0.05	0.08	0.029
Pipe 8	6.00	0.05	0.08	0.029
Pipe 9	12.00	0.10	0.41	0.039
Pipe 10	6.00	0.20	3.41	0.040
Pipe 11	6.00	0.20	3.41	0.040
Pipe 12	6.00	0.20	3.41	0.040
Pipe 13	6.00	0.20	3.41	0.040
Pipe 14	78.00	2.65	373.70	0.026
Pipe 15	6.00	0.20	3.41	0.040
Pipe 16	6.00	0.20	3.41	0.040
Pipe 17	42.00	0.36	3.74	0.029

Pressioni nei nodi

Node ID	Demand LPM	Head m	Pressure m	Quality
Junc 1	6.00	359.75	38.75	0.00
Junc 2	6.00	359.75	39.75	0.00
Junc 3	6.00	359.75	40.75	0.00
Junc 4	6.00	359.75	42.75	0.00
Junc 5	6.00	359.40	43.40	0.00
Junc 6	6.00	359.38	44.38	0.00
Junc 7	6.00	351.39	37.39	0.00
Junc 8	6.00	351.39	37.39	0.00
Junc 9	6.00	359.75	43.75	0.00
Junc 10	6.00	359.71	43.71	0.00
Junc 11	6.00	359.71	43.71	0.00
Junc 12	6.00	354.68	38.68	0.00
Junc 13	6.00	351.31	35.31	0.00
Junc 14	6.00	354.64	38.64	0.00
Junc 15	6.00	347.90	31.90	0.00
Junc 17	18.00	327.96	13.96	0.00